



**STATE OF HAWAII
OFFICE OF HAWAIIAN AFFAIRS
560 NORTH NIMITZ HIGHWAY, SUITE 200
HONOLULU, HAWAII 96817**

February 11, 2019

**REQUEST FOR QUOTE LAF 2019-18
INSTALLATION OF THREE (3) ELECTRICAL CIRCUITS
ADDENDUM No. 01**

AMENDMENTS TO ORIGINAL REQUEST FOR QUOTE

- 1) The information regarding the submission of quotes on page 1 of the RFQ LAF 2019-18 reads:

Interested Offerors are strongly encouraged to attend a site inspection. It will be held on Friday, February 8, 2019 at 10:00 a.m.

The information regarding the submission of quotes on page 1 of the RFQ LAF 2019-18 is hereby amended to read as follows:

Interested Offerors are strongly encouraged to attend a site inspection. It will be held on Friday, February 8, 2019 at 10:00 a.m. **A second site inspection has been added for Interested Offerors who were unable to attend the first site inspection. It will be held on Wednesday, February 13, 2019 at 2:00 p.m.** All interested parties shall meet at the OHA's reception desk in Suite 200 at Na Lama Kukui. Please contact Jennifer Lau, Procurement Specialist, by email at jenniferl@oha.org or by phone at (808) 594-1815, if you will be attending the site inspection.

- 2) Item 2 on page 1 under the Scope of Work of the RFQ LAF 2019-18 reads:

2. Securing, fastening, rough-in
 - a. Conduits can be strapped to existing uni-strut for part of the run;
 - b. Part of conduit run will be in sheet rock and above ceiling tiles; and
 - c. Conduits/outlets in kitchen area to be non-surface mount.

Item 2 on page 1 under the Scope of Work of the RFQ LAF 2019-18 is hereby amended to read as follows:

2. Securing, fastening, rough-in

- a. Conduits can be strapped to existing uni-strut for part of the run;
- b. Part of conduit run will be in sheet rock and above ceiling tiles;
- c. Conduits/outlets in kitchen area to be non-surface mount; **and**
- d. **Walls must be patched and painted as well as the new conduit after electrical work is completed.**

QUESTIONS & ANSWERS

- 1) Do the walls have to be painted?

Yes, the vendor needs to paint the wall. We may have the matching paint color in the storage but we will need to check. We can also provide the name of the matching paint color.

- 2) If permits need to be obtained, can the vendor obtain the building plans?

Yes, they will be available.

- 3) Will the mounts need to be surfaced or recessed?

The mounts need to be recessed.

- 4) Is there an option to work on the weekends or at night?

It would need to be scheduled.